

Environment Act Licence

Manitoba
Environment



Licence No. 1693

Issue Date JULY 7, 1993

In accordance with the Manitoba Environment Act (C.C.S.M. c. E125)

THIS LICENCE IS ISSUED TO:

RURAL MUNICIPALITY OF DE SALABERRY: "the Licencee"
OTTERBURNE WASTEWATER TREATMENT LAGOON

for the construction and operation of the Development being a wastewater collection system and a wastewater treatment lagoon located in the northwest quarter of Section 24, Township 6, Range 3 EPM in the Rural Municipality of De Salaberry and with discharge of treated effluent to a municipal drain that flows into the Rat River and subject to the following specifications, limits, terms and conditions:

DEFINITIONS

In this Licence,

"appurtenances" means machinery, appliances, or auxiliary structures attached to a main structure to enable it to function, but not considered an integral part of it;

"ASTM" means the American Society for Testing and Materials;

"bentonite" means specially formulated standard mill grade sodium bentonite conforming to American Petroleum Institute Specification 13-A;

"cut-off" means a vertical-side trench filled with compacted clay or a wall constructed from compacted clay;

"Director" means an employee so designated pursuant to The Environment Act;

"effluent" means treated wastewater flowing or pumped out of the wastewater treatment lagoon;

"fecal coliform" means aerobic and facultative, Gram-negative, nonspore-forming, rod-shaped bacteria capable of growth at 44.5 °C, and associated with fecal matter of warm-blooded animals;

"five-day biochemical oxygen demand" means that part of the oxygen demand usually associated with biochemical oxidation of organic matter within 5 days at a temperature of 20°C;

"hydraulic conductivity" means the quantity of water that will flow through a unit cross-sectional area of a porous material per unit of time under a hydraulic gradient of 1.0;

"in-situ" means on the site;

"MPN Index" means the most probable number of coliform organisms in a given volume of wastewater which, in accordance with statistical theory, would yield the observed test result with the greatest frequency;

"primary cell" means the first in a series of cells of the wastewater treatment lagoon system and is the cell that receives the untreated wastewater;

"riprap" means small, broken stones or boulders placed compactly or irregularly on dykes or similar embankments for protection of earth surfaces against wave action or current;

"secondary cell" means a cell of the wastewater treatment lagoon system and is the cell that receives partially treated wastewater from the primary cell;

"septage" means the sludge produced in individual on site wastewater disposal systems such as septic tanks;

"total coliform" means a group of aerobic and facultative anaerobic, Gram-negative, nonspore-forming, rod-shaped bacteria, that ferment lactose with gas and acid formation within 48 hours at 35 °C, and inhabit predominantly the intestines of man or animals, but are occasionally found elsewhere and include the sub-group of fecal coliform bacteria.

GENERAL REQUIREMENTS

1. The Licencee shall direct all sewage generated within the hamlet of Otterburne toward the wastewater treatment lagoon or other approved sewage treatment facilities.
2. The Licencee shall operate and maintain the wastewater treatment lagoon in such a manner that:
 - (a) the release of offensive odours is minimized;
 - (b) the organic loading on the primary cell, as indicated by the five-day biochemical oxygen demand, is not in excess of 56 kilograms per hectare per day; and
 - (c) the depth of liquid in the primary cell does not exceed 1.5 metres.
3. The Licencee shall ensure that septage is not discharged into the wastewater treatment lagoon between the 15th day of October of any year and the 1st day of June of the following year.

4. The Licencee shall ensure that the discharge of septage into the wastewater treatment lagoon does not exceed 9000 litres of septage during any 7 day period.
5. The Licencee shall, in case of physical or mechanical breakdown of the wastewater collection and/or treatment system:
 - (a) notify the Director immediately;
 - (b) identify the repairs required to the wastewater collection and/or treatment system;
 - (c) undertake all repairs to minimize unauthorized discharges of wastewater; and
 - (d) complete the repairs in accordance with any written instructions of the Director.
6. The Licencee shall install and maintain a fence around the wastewater treatment lagoon to limit access.

CONSTRUCTION SPECIFICATIONS

7. The Licencee shall, prior to the construction of the dykes for the wastewater treatment lagoon:
 - (a) remove all organic topsoil from the area where the dykes will be constructed; or
 - (b) remove all organic material for a depth of 0.3 metres and a width of 3.0 metres from the area where the cut-off will be constructed.
8. The Licencee shall construct:
 - (a) the wastewater treatment lagoon with a continuous clay liner under all interior surfaces of the structure in accordance with the following specifications:
 - (i) the liner shall be constructed of clay;
 - (ii) the liner shall be at least 1 metre thick;
 - (iii) the liner shall have a hydraulic conductivity of 1×10^{-7} centimetres per second or less;

- (iv) the liner shall be constructed to an elevation of 2.5 metres above the floor elevation of the secondary cell; and
- (b) a cut-off in the exterior dykes of the wastewater treatment lagoon in accordance with the following specifications:
 - (i) the cut-off shall be constructed of clay which has been mechanically compacted;
 - (ii) the cut-off shall be at least 1 metre thick;
 - (iii) the cut-off shall have a hydraulic conductivity of 1×10^{-7} centimetres per second or less; and
 - (iv) the cut-off shall be constructed to an elevation of 2.5 metres above the floor elevation of the secondary cell.

DISCHARGE LIMITS, TERMS AND CONDITIONS

9. The Licencee shall not discharge effluent from the wastewater treatment lagoon:
- (a) where the organic content of the effluent, as indicated by the five day biochemical oxygen demand, is in excess of 30 milligrams per litre;
 - (b) where the fecal coliform content of the effluent, as indicated by the MPN index, is in excess of 200 per 100 millilitres of sample;
 - (c) where the total coliform content of the effluent, as indicated by the MPN index, is in excess of 1500 per 100 millilitres of sample; or
 - (d) between the 1st day of November of any year and the 15th day of June of the following year.


MONITORING AND REPORTING SPECIFICATIONS

10. The Licencee shall arrange with the designated Environment Officer a mutually acceptable time and date for any required soil sampling between the 15th day of May and the 15th day of October of any year.
11. The Licencee shall subject undisturbed soil samples from the lagoon liner including the cut-off; to hydraulic conductivity tests, the number and location of samples to be specified by the designated Environment Officer up to a maximum of twenty samples.

12. The Licencee shall provide a drill rig which is acceptable to the designated Environment Officer to extract soil samples from the liner and the cut-off.
13. The Licencee shall, not less than 2 weeks before the wastewater treatment lagoon is placed in operation, submit to the Director the results of the tests carried out pursuant to Clause 11.
14. The Licencee shall, on or before the 1st day of July, 1994, provide to the Director "as constructed" drawings of the wastewater treatment lagoon and all appurtenances.

REVOCATION

If in the opinion of the Director the Licencee has exceeded or is exceeding or has or is failing to meet the specifications, limits, terms, or conditions set out herein, the Director may revoke, temporarily or permanently, this Licence.



Larry Strachan, P. Eng.
Director
Environment Act

FILE: 3502.00