

Environment Act Licence

Manitoba
Environment



Licence No. 1730
Issue Date DECEMBER 17, 1993

In accordance with the Manitoba Environment Act (C.C.S.M. C.E125)

THIS LICENCE IS ISSUED TO:

CITY OF WINNIPEG.: "the Licencee"

for the construction and operation of the Development being a Water Treatment System (Wastewater) facility located in Township 8, Range 17 E.P.M., for the de-chlorination and discharge of screen backwash water, fire pump cooling water, and low lift pump cooling water to the waters of Falcon Bay, and subject to the following specifications, limits, terms and conditions:

DEFINITIONS

In this Licence,

"De-chlorination system" means the infrastructure to de-chlorinate the screen backwash water, fire pump cooling water, and low lift pump cooling water;

"Director" means an employee so designated under The Environment Act;

"Discharge line" means the pipe carrying the de-chlorinated screen backwash water, fire pump cooling water, and low lift pump cooling water to the waters of Falcon Bay.

GENERAL SPECIFICATIONS

1. The Licencee shall ensure that domestic wastewater is not directed to the discharge line.
2. The Licencee shall ensure that laboratory wastes are not directed to the discharge line.
3. The Licencee shall, in case of physical or mechanical breakdown of the de-chlorination system or discharge line:
 - (a) notify the Director immediately;
 - (b) identify the repairs required to the wastewater collection and/or treatment system; and
 - (c) complete the repairs in accordance with the written instructions of the Director.


4. Unless otherwise specified, all laboratory analyses shall be conducted in accordance with the latest edition of "Standard Methods For The Examination Of Water and Wastewater."

LIMITS, TERMS, AND CONDITIONS

5. The Licencee shall not discharge screen backwash water, fire pump cooling water or low lift pump cooling water where the total chlorine residual is in excess of 0.2 milligrams per litre.

REVIEW OR REVOCATION

If in the opinion of the Director the Licencee has exceeded or is exceeding the specifications, limits, terms, or conditions set out herein, the Director may revoke, temporarily or permanently, this Licence.



Larry Strachan, P. Eng.
Director, Environment Act

FILE NO: 3656.00