

AN ORDER OF THE CLEAN ENVIRONMENT COMMISSION
UNDER THE CLEAN ENVIRONMENT ACT

258 ms

Re: The Clean Environment Commission and the Rural Municipality of Springfield, applicant.

WHEREAS pursuant to the provisions of The Clean Environment Act, the Rural Municipality of Springfield, Oakbank, Manitoba has submitted an application to the Clean Environment Commission requesting the Commission to prescribe limits in connection with the operation of a sewage lagoon system to service the unincorporated village of Oakbank, said lagoon being located in the NW¹/₄ of Section 22-11-5 East of the Principal Meridian with effluent discharge into municipal drains leading to Cook's Creek, the drainage system being partially in the Additional Zone of the City of Winnipeg and partially in the Rural Municipality of Springfield,

AND WHEREAS a representation was made to the Clean Environment Commission by a person who is or is likely to be affected by an order of the Commission prescribing limits in connection with said operation,

AND WHEREAS the Clean Environment Commission held a public hearing on the 19th day of March 1973 in Building 2 of the Fort Osborne Complex at 139 Tuxedo Avenue in the City of Winnipeg,

AND WHEREAS the Clean Environment Commission considered the application on the 24th day of April 1973,

IT IS HEREBY ORDERED THAT:

1. The applicant shall ensure that all the facilities for the treatment of sewage and the holding of effluent are constructed of impervious materials and said facilities are maintained and operated in such a manner as to prevent the contamination of ground water.
2. The applicant shall ensure that said sewage lagoon system is operated in such a manner as to minimize the release of offensive odours.
3. The applicant shall ensure that the biochemical oxygen demand loading on the primary cell of said sewage lagoon system does not exceed 50 pounds per acre per day,
4. The applicant shall ensure that the quality of the final effluent from said sewage lagoon system is such that:

. . . 2


*assigned to
D.A.B., Eng. Dept.,
May 10/73.
D.M.M./ms.*

C-6-608

- a. the biochemical oxygen demand does not exceed 30 milligrams per litre and,
- b. the total coliform MPN index does not exceed 1500 per 100 millilitres of sample,
- c. at the point where it enters the Additional Zone of the City of Winnipeg the suspended solids content does not exceed 30 milligrams per litre and the grease content is 0 milligrams per litre,
6. The applicant shall ensure that no discharge of effluent from said holding pond takes place between the first day of November in any year and the fifteenth day of May in the following year.

Order No. 258

Dated at this City of Winnipeg
this 4th day of May 1973.


Chairman,
Clean Environment Commission.

C-b-603

CC: Regional Services
Aug 17/73