

AN ORDER OF THE CLEAN ENVIRONMENT COMMISSION
UNDER THE CLEAN ENVIRONMENT ACT

Re: The Clean Environment Commission and Northern Pines Developments applicant,

WHEREAS pursuant to the provisions of The Clean Environment Act Mr. R. G. White, on behalf of Northern Pines Developments, has submitted an application to The Clean Environment Commission to prescribe limits in connection with the operation of a sewage lagoon system with effluent drainage in a westerly direction to a swamp area and hence towards the Pasquia River: the said sewage lagoon system to serve a trailer home court and a tourist development consisting of a restaurant, service station, motel, overnight trailer court and other facilities, all located on part of the NW $\frac{1}{4}$ of Section 2-55-26 WPM in the Local Government District of Consul, in the Province of Manitoba,

AND WHEREAS no representation was made to The Clean Environment Commission by any person who is, or is likely to be, affected by an Order of the Commission prescribing limits in connection with the said operation,

AND WHEREAS The Clean Environment Commission considered the application on the 25th day of June, 1974,

IT IS HEREBY ORDERED THAT

1. The applicant shall ensure that all facilities for the treatment of sewage and the holding of effluent are constructed of impervious materials and the said facilities are maintained and operated in such a manner as to prevent the contamination of groundwater,
2. The applicant shall ensure that the said sewage lagoon system is operated in such a manner as to minimize the release of offensive odours,
3. The applicant shall ensure that the biochemical oxygen demand (5-day BOD) loading on the primary cell of the said lagoon system does not exceed 50 pounds per acre, per day,

*Assigned to
Eng. Apps.
July 19/74
A.B.M./m.d.*

4. The applicant shall ensure that the quality of the final effluent from the said sewage lagoon system is such that:
 - (a) the biochemical oxygen demand (5-day BOD) does not exceed 30 milligrams per litre, and
 - (b) the total coliform content as indicated by the MPN index does not exceed 1500 per 100 millilitres of sample,

5. The applicant shall ensure that no discharge of effluent from the said sewage lagoon system takes place in the period between the 1st day of November of any year and the 15th day of May of the following year.

Order No. 371

Dated at the City of Winnipeg

this 17th day of July 1974

C-b- 845


Chairman
The Clean Environment Commission