

cc: Registrar
Aug 28/73

Approved by Engg Dept
20 Sept 73
W.C. McLean

Chairman,
The Clean Environment Commission.

Robert Ham

- 1) The contaminants or wastes shall be treated in the said sewage treatment plant so that the level of the biochemical oxygen demand of the effluent shall not exceed thirty milligrams per litre, at the time of release to the Nelson River.
 - 2) The effluent shall be chlorinated to a residual of 0.5 milligrams per litre after 15 minutes contact before discharge.
 - 3) The operation shall be carried out in such a manner as to minimize the release of offensive odours and to the satisfaction of the Commission.
 - 4) The loading on the plant shall not exceed 25 pounds of biochemical oxygen demand per day.
- This licence is issued pursuant to The Clean Environment Act permitting the Frontier School Division to discharge contaminants or waste arising from the operation of a secondary-treatment package sewage plant for the Jack River School, Norway House, subject to the following conditions:

Re: ORDINARY LICENCE - FRONTIER SCHOOL DIVISION,
JACK RIVER SCHOOL, NORWAY HOUSE,
SEWAGE DISPOSAL SYSTEM.

July 14, 1970.

304-401 YORK AVE., WINNIPEG 1
TELEPHONE 946-7756 If no answer call 946-7982

C-6-263

(47)



Province of Manitoba, Department of Health
CLEAN ENVIRONMENT COMMISSION

