

AN ORDER OF THE CLEAN ENVIRONMENT COMMISSION

UNDER THE CLEAN ENVIRONMENT ACT

RE: THE CLEAN ENVIRONMENT COMMISSION and THE RURAL MUNICIPALITY OF DE SALABERRY,
Applicant,

WHEREAS pursuant to the provisions of the Clean Environment Act, the Rural Municipality of De Salaberry submitted an application to the Department of Mines, Resources and Environmental Management in connection with the operation of a sewage lagoon system with discharge of effluent via a ditch and the St. Malo Canal to the Rat River, the said sewage system being located in Legal Subdivision 9, 10, 11, 14, 15 & 16, Section 14-4-4 East, all of Plans 9083, 530, 3958, 8627, 4826, 7631, 9179 and 10693, South Part of Parcel 7, Plan 9172, Roll #167800 and 168000, Lot 98 and remainder of Lot 99, Plan 4825 all in the St. Malo Settlement, Manitoba;

AND WHEREAS in the absence of limits being prescribed by a Regulation under the said Act, the application was referred to The Clean Environment Commission for the prescribing of limits;

AND WHEREAS no representation was made to The Clean Environment Commission by any person who is or who is likely to be affected by an Order of the said Commission prescribing limits in connection with the said operation;

AND WHEREAS the Clean Environment Commission considered the said application on the 12th day of September, 1977;

IT IS HEREBY ORDERED THAT

1. The Applicant shall ensure that the said sewage lagoon system is constructed, maintained and operated in such a manner as to:
 - (a) prevent the contamination of groundwater;
 - (b) minimize the release of offensive odours;
 - (c) prevent leakage from the said system onto adjacent lands.

BINDER COPY

AN ORDER OF THE CLEAN ENVIRONMENT COMMISSION
 UNDER THE CLEAN ENVIRONMENT ACT

RE: THE CLEAN ENVIRONMENT COMMISSION and THE RURAL MUNICIPALITY OF DE SALABERRY,
 Applicant,

WHEREAS pursuant to the provisions of the Clean Environment Act, the Rural Municipality of De Salaberry submitted an application to the Department of Mines, Resources and Environmental Management on behalf of the Town of Gimli in connection with the operation of a sewage lagoon system with discharge of effluent via a ditch and the St. Malo Canal to the Rat River, the said sewage system being located in legal subdivision 9, 10, 11, 14, 15 & 16, Section 14-4-4 East, all of Plans 9083, 530, 3958, 6827, 4826, 7631, 9179 and 10693, South Part of Parcel 7, Plan 9172, Roll #167800 and 168000, Lot 98 and remainder of Lot 99, Plan 4825 all in the St. Malo Settlement, Manitoba;

AND WHEREAS in the absence of limits being prescribed by a Regulation under the said Act, the application was referred to The Clean Environment Commission for the prescribing of limits;

AND WHEREAS no representation was made to The Clean Environment Commission by any person who is or who is likely to be affected by an Order of the said Commission prescribing limits in connection with the said operation;

AND WHEREAS the Clean Environment Commission considered the said application on the 12th day of September, 1977;

IT IS HEREBY ORDERED THAT

1. The Applicant shall ensure that the said sewage lagoon system is constructed, maintained and operated in such a manner as to:
 - (a) prevent the contamination of groundwater;
 - (b) minimize the release of offensive odours;
 - (c) prevent leakage from the said system onto adjacent lands.

*assigned to W.P.C.
 77 1013
 C.B./ci*

2. The Applicant shall ensure that the organic loading on the primary cell of the said system, in terms of five-day biochemical oxygen demand, is not in excess of 50 pounds per acre per day.
3. The Applicant shall ensure that no discharge of effluent takes place between the 1st day of November of any year and the 15th day of May of the following year without the written permission of the Environmental Management Division of the Department of Mines, Resources and Environmental Management.
4. The Applicant shall ensure that the quality of the effluent from the said sewage treatment lagoon system is such that:
 - (a) the five-day biochemical oxygen demand is not in excess of 30 milligrams per litre;
 - (b) the total coliform content, in terms of the MPN Index, is not in excess of 1500 per 100 millilitres of sample.

Order No. 753

Dated at the City of Winnipeg

this 11th day of October, 1977.


Chairman,
The Clean Environment Commission.

C-b-380.1