

Binder Copy

AN ORDER OF THE CLEAN ENVIRONMENT COMMISSION
 UNDER THE CLEAN ENVIRONMENT ACT

RE: THE CLEAN ENVIRONMENT COMMISSION and the VILLAGE OF WINNIPEGOSIS, Applicant,

WHEREAS pursuant to the provisions of The Clean Environment Act, the Village of Winnipegosis filed an application with the department in connection with the operation of an existing sewage lagoon system located in Blocks 9 and 10, Plan 219, in the SE¼ of Section 15, Township 31, Range 18 WPM in the Village of Winnipegosis, Manitoba, with discharge of effluent to Lake Winnipegosis;

AND WHEREAS in the absence of limits, terms and conditions prescribed by a regulation under the said Act, the application was referred to The Clean Environment Commission for the prescribing of limits, terms and conditions;

AND WHEREAS after giving notice of the application, the Commission issued Order No. 907 on the 12th day of February, 1981;

AND WHEREAS on the 4th day of March, 1982, the Applicant requested the Commission to vary the terms of the said order to extend to the 1st day of November, 1986, the requirement in the order for lagoon expansion or replacement and for the coming into force of effluent quality limits;

AND WHEREAS the Commission held a hearing in Winnipegosis on the 13th day of April, 1982, to consider the variation request and further considered the matter on the 31st day of May, 1982;

IT IS HEREBY ORDERED THAT ORDER NO. 907 BE VARIED TO READ AS FOLLOWS:

1. The Applicant shall, on or before the 1st day of November, 1982, file with the Environmental Management Division:
 - (a) a report of investigations carried out to determine the sources of infiltration to the sewage collection and treatment facilities serving the said Village of Winnipegosis;
 - (b) an engineering report describing in detail the modifications, repairs, or upgrading works proposed by the Applicant to overcome excessive hydraulic loading of the said sewage lagoon system.

*Assigned
 TO
 WPC
 June 11/82
 JH*

2. The Applicant shall provide, maintain and operate sewage collection and treatment facilities serving the said Village of Winnipegosis in such a manner that:
- (a) the possibility of groundwater contamination is minimized;
 - (b) the release of offensive odours is minimized;
 - (c) there is no discharge of effluent:
 - (i) where the faecal coliform content of the effluent, as indicated by the MPN index, is in excess of 200 per 100 millilitres of sample;
 - (ii) on and after the 1st day of November, 1984, where the organic content of the effluent, as indicated by the five day biochemical oxygen demand, is in excess of 30 milligrams per litre;
 - (iii) subject to (iv), between the 1st day of November of any year and the 1st day of May of the following year without the express written permission of the Environmental Management Division;
 - (iv) on and after the 1st day of November, 1984, between the 1st day of November of any year and the 1st day of May of the following year;
 - (d) on and after the 1st day of November, 1984, the organic loading on the primary cell, in terms of the five day biochemical oxygen demand, is not in excess of 56 kilograms per day.
3. Order No. 907, as varied by The Clean Environment Commission, is hereby designated as Order No. 907VC:

Order No. 907VC

Dated at the City of Winnipeg
this 10th day of June, 1982.


Chairman,
The Clean Environment Commission.

File: 62.1