

Webb, Bruce (CWS)

To: Steele, Tania (CWS)
Subject: RM of Montcalm - St. Jean Wastewater Treatment Lagoon and Forcemain File: 5435.10

The attached material can be placed in the public registries for the above project:

Additional Information Request: No additional information was requested.

Public Comments on Environment Act Proposal: No public comments received.

Technical Advisory Committee Comments on Environment Act Proposal: (9 pages)

Manitoba Conservation and Water Stewardship – Lands Branch, May 22, 2014

Manitoba Conservation and Water Stewardship – Lands Branch, Land Management and Planning Section, April 22, 2014

Manitoba Conservation and Water Stewardship – Parks and Protected Spaces Branch, May 13, 2014

Manitoba Conservation and Water Stewardship – Wildlife Branch, May 9, 2014

Manitoba Conservation and Water Stewardship – Office of Drinking Water, May 14, 2014

Manitoba Conservation and Water Stewardship – Water Use Licensing Section, April 17, 2014

Manitoba Conservation and Water Stewardship – Water Control Works and Drainage Licensing Section, April 28, 2014

Manitoba Infrastructure and Transportation – Highway Planning and Design Branch, Environmental Services Section,
May 8, 2014

Manitoba Infrastructure and Transportation – Hydrologic Forecasting Branch, April 22, 2014

Bruce.

Webb, Bruce (CWS)

From: Kaita, Adara (CWS) on behalf of +WPG1212 - Conservation_Circulars (CWS)
Sent: May-22-14 8:56 AM
To: Webb, Bruce (CWS) *BW*
Subject: EA Proposal - RM Montcalm - St. Jean lagoon - File: 5435.10

Hi Bruce,

The Lands Branch has no concerns as there are no Crown lands impacted by this proposal.

Thank you for the opportunity to review.

Adara Kaita

Crown Land Programs and Policy Manager
Lands Branch | Conservation and Water Stewardship
Box 25, 200 Saulteaux Crescent | Winnipeg, MB R3J 3W3
Cell: (204) 945-6301 | F: (204) 948-2197

Webb, Bruce (CWS)

Subject: FW: Review & Comments - RM Montcalm St. Jean lagoon File: 5435.10 - Due May 20, 2014

From: Sobkowich, Dale (CWS)

Sent: April-22-14 1:31 PM

To: Webb, Bruce (CWS)

Subject: RE: Review & Comments - RM Montcalm St. Jean lagoon File: 5435.10 - Due May 20, 2014

Land Management & Planning Section has no comment as the surface tenure is under private ownership

Dale Sobkowich
Lands Branch

Webb, Bruce (CWS)

Subject: FW: Review & Comments - RM Montcalm St. Jean lagoon File: 5435.10 - Due May 20, 2014

From: Kelly, Jason (CWS)

Sent: May-13-14 5:39 PM

To: Webb, Bruce (CWS) *BW*

Subject: RE: Review & Comments - RM Montcalm St. Jean lagoon File: 5435.10 - Due May 20, 2014

Parks and Protected Spaces Branch has reviewed the proposal filed pursuant to the *Environment Act* for Review & Comments - RM Montcalm St. Jean lagoon File: 5435.10 - Due May 20, 2014. The Branch has no comments or concerns to offer as it does not affect any provincial parks, park reserves, ecological reserves, areas of special interest or proposed protected areas.

Jason Kelly, M.N.R.M.
Ecological Reserves and Protected Areas Specialist
Parks and Protected Spaces Branch
Conservation and Water Stewardship
Box 53, 200 Saulteaux Cres
Winnipeg, MB R3J 3W3

Phone: 204-945-4148

Cell:

Fax: 204-945-0012

Email: Jason.Kelly@gov.mb.ca

Webb, Bruce (CWS)

From: Boissonneault, Caroline (CWS)
Sent: May-09-14 10:38 AM
To: Webb, Bruce (CWS) *BW*
Subject: Emailing: Review Comments - RM Montcalm St. Jean lagoon File 5435.10 - Due May 20 2014
Attachments: Review & Comments - RM Montcalm St. Jean lagoon File: 5435.10 - Due May 20, 2014

Hi Bruce,
Wildlife Branch has reviewed the proposal and has no concerns with it.
Thank you.
Caroline Boissonneault
Conservation and Water Stewardship
Wildlife Branch
Tel.: 204-945-6810
Caroline.boissonneault@gov.mb.ca

Your message is ready to be sent with the following file or link attachments:

Review Comments - RM Montcalm St. Jean lagoon File 5435.10 - Due May 20 2014

Note: To protect against computer viruses, e-mail programs may prevent sending or receiving certain types of file attachments. Check your e-mail security settings to determine how attachments are handled.

Webb, Bruce (CWS)

From: Stibbard, James (CWS)
Sent: May-14-14 8:55 AM
To: Webb, Bruce (CWS) BW
Subject: Re: 5435.10 RM of Montcalm. St. Jean WW Lagoon EAP

Mr. Webb,

I reviewed the above noted EAP. The proposed treated effluent discharge point to the Red River is several miles (the EAP did not say exactly how many, but it is not far) upstream of the raw water intake for the Morris Regional Water Treatment Plant. The EAP notes normal treated effluent discharged from the proposed lagoon will meet Manitoba Conservation quality guidelines and will not be a threat to the environment. It should also not present problems for the Morris water plant. However, if a major spill of untreated or partially treated water to the river were to occur, it would have the potential to affect the treatment process at Morris.

As such, Office of Drinking Water recommends a provision be included in the Operating Licence for the proposed lagoon that the Owner of the lagoon have contact information for the Morris Regional Water Treatment Plant in the Emergency Response Plan for the lagoon with a requirement that, in the event off a major spill of untreated or partially treated effluent from the lagoon, the Morris water plant be contacted.

Apart from this, Office of Drinking Water has no other concerns with this EAP or the proposed development.

If you have any questions, please call.

Regards,

James Stibbard P. Eng.
Approvals Engineer
Office of Drinking Water
1007 Century Street
Winnipeg MB R3H 0W4
phone: (204) 945-5949
fax: (204) 945-1365
email: James.Stibbard@gov.mb.ca
website: www.manitoba.ca/drinkingwater

Confidentiality Notice: This message, including any attachments, is confidential and may also be privileged and all rights to privilege are expressly claimed and not waived. Any use, dissemination, distribution, copying or disclosure of this message, or any attachments, in whole or in part, by anyone other than the intended recipient, is strictly prohibited.

Webb, Bruce (CWS)

Subject: FW: Review & Comments - RM Montcalm St. Jean lagoon File: 5435.10 - Due May 20, 2014

From: Matthews, Rob (CWS)

Sent: April-17-14 9:29 AM

To: Webb, Bruce (CWS)

Subject: RE: Review & Comments - RM Montcalm St. Jean lagoon File: 5435.10 - Due May 20, 2014

No concerns.

Rob Matthews, WULS, CWS.

Webb, Bruce (CWS)

From: Roberts, Dan (CWS)
Sent: April-28-14 11:12 AM BW
To: Webb, Bruce (CWS)
Subject: Review & Comments - RM Montcalm St. Jean lagoon File: 5435.10 - Due May 20, 2014
Attachments: Drainage Licence Application.pdf

Any water control works (drains, culverts, dykes, dams, etc.) associated with this project will require licensing under the *Water Rights Act* – an application is attached for the proponent's convenience. Any inquiries in this regard may be directed to the local *Water Resource Officer*. Their contact information may be found at:

http://www.gov.mb.ca/conservation/waterstewardship/licensing/pdf/areas_of_focus_jan_23_12.pdf

Sincerely,

Dan Roberts
Water Resource Officer
Water Control Works and Drainage Licensing Section
Conservation and Water Stewardship
Box 640, 201 Fourth Ave. S., Swan River, MB R0L 1Z0
Cell: (204) 281-2122, Fax: 734-3733



Infrastructure and Transportation
Highway Planning and Design Branch
Environmental Services Section
1420 - 215 Garry St., Winnipeg, MB R3C 3P3
T (204) 619-4359 F (204) 946-0593

May 8, 2014

Tracey Braun, M. Sc. *TB*
Director, Environmental Approvals Branch
Manitoba Conservation and Water Stewardship
123 Main St., Suite 180
Winnipeg, MB R3C 1A5

RE: RM of Montcalm - St. Jean WWTL and Forcemain
Client File No 5435.10

Dear Ms. Braun:

MIT has reviewed The Environment Act Proposal noted above and we do not have concerns with the development provided that necessary permits will be acquired from the Highway Traffic Board for any structures placed within the control area of PTH 75.

For more information, please contact:

Murray Chornoboy
Regional Planning Technologist
(204) 348-6287
Murray.Chornoboy@gov.mb.ca

Thank you very much for providing us the opportunity to review the proposal.

Sincerely,

Ryan Coulter, M. Sc., P. Eng.
Manager of Environmental Services

Infrastructure and Transportation

.....

DATE: April 22, 2014

TO: Bruce Webb *BLW*
Water Development and
Assessments Officer
Environmental Approvals Branch
Manitoba Conservation and Water
Stewardship
Box 80 160-123 Main Street
Winnipeg MB R3C 1A5

FROM: Brad Allum
Development Review Officer
Hydrologic Forecasting
Manitoba Infrastructure and Transportation
Box 14 – 200 Saulteaux Crescent
Winnipeg MB R3J 3W3

PHONE NO: (204) 945-2121
FAX NO: (204) 945-7419
E-MAIL: brad.allum@gov.mb.ca
FILE NO: 10.4.2 R.M. of Montcalm

SUBJECT: Rural Municipality of Montcalm
St. Jean Baptiste
Faculative Lagoon and Forcemain
File 5435.1

The site of the St. Jean lagoon is within the Red River Valley Designated Flood Area.

Section 2.6.7.1 Topography, of the Environment Act Proposal as prepared by J.R. Cousin Consultants Ltd. indicates that the crest elevation of the lagoon dikes will be at the Flood Protection Level of 239.7 metres (786.4 feet) G.S. of C. Datum. The Flood Protection Level, as indicated in our comments of January 15, 2010 regarding EAP 5435, is 239.76 metres (786.6 feet).

The dike side slopes, both interior and exterior will be constructed to 4H:1V grades.

While Hydrologic Forecasting has no objections to the approval of EAP 5435.1 Montcalm for the purposes indicated, dike crest must be at 239.76 metres (786.6 feet).

In accordance with Manitoba Regulation 59/2002, a regulation under The Water Resources Administration Act, the Rural Municipality of Montcalm must obtain a Designated Flood Area Permit for the dike prior to the commencement of construction.

Permit application will be forwarded to the municipality under separate cover.

ORIGINAL SIGNED BY

Brad Allum

BA